Notified body No. 1134
asbl **ANPI** vzw
Parc Scientifique Fleming - Granbonpré 1
B-1348 Louvain-la-Neuve

003-PROD
ISO/IEC 17065

CERTIFICATE OF CONSTANCY OF PERFORMANCE

1134-CPR-097

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the products Construction Products Regulation or CPR), this certificate applies to the construction product

Manual call point with short-circuit isolator Kingspan MCP-A

with the variants and the performances listed in annex of this certificate and for the intended use:
Fire safety

manufactured by or for

Kingspan Light + Air Belgium NV
Anthonis De Jonghestraat 50
9100 Sint-Niklaas
Belgium

and produced in the manufacturing plant

Kingspan Light + Air Belgium NV
Anthonis De Jonghestraat 50
9100 Sint-Niklaas
Belgium

This certificate attests that all provisions concerning the assessment and the verification of constancy performance and the performances described in Annex ZA of the standard(s):

EN 54-11:2001/A1:2005
EN 54-17:2005/AC:2007

under system 1 are applied and that

the products fulfil all prescribed requirements set out above.

This certificate was first issued on 2014-12-09 and remains valid as a long time as the testing methods and/or for the control of the production in factory included in the harmonized standard, used to evaluate the performances of the declared characteristics, do not change and as neither the product, nor the manufacturing conditions in the plant or the factory production control itself are not modified significantly.

Brussels, 24 October 2024

Marie Majerus
Certification Manager

This certificate and the annexes may only be copied completely and without any alteration.
cert@anpi.be - www.anpi.be

Notified body No. 1134
asbl **ANPI** vzw
Parc Scientifique Fleming - Granbonpré 1
B-1348 Louvain-la-Neuve

003-PROD
ISO/IEC 17065

Annex 1 to the CERTIFICATE CONSTANCY OF PERFORMANCE

1134-CPR-097

Variants of the Kingspan MCP-A

Manual call point with short-circuit isolator
Variants: MCP

Brussels, 24 October 2024

Marie Majerus
Certification Manager

This certificate and the annexes may only be copied completely and without any alteration.
cert@anpi.be - www.anpi.be

Notified body No. 1134
asbl **ANPI** vzw
Parc Scientifique Fleming - Granbonpré 1
B-1348 Louvain-la-Neuve

003-PROD
ISO/IEC 17065

Annex 2 to the CERTIFICATE CONSTANCY OF PERFORMANCE

1134-CPR-097

Harmonised technical specification	**EN 54-11:2001/A1:2005**	
Essential Characteristics	**Performance**	**Clause**
Nominal activation conditions / Sensitivity and Performance under fire conditions		
- Alarm condition	pass	4.3.2
- Indicators for alarm condition	pass	4.4
- Safety aspects	pass	4.7.1
- Protection against accidental operation	NA	4.7.4
- Operational performance test	pass	5.2
- Function test	pass	5.3
Operational reliability		
- Marking and data	pass	4.2
- Normal condition	pass	4.3.1
- Reset facility	pass	4.5
- Test facility	pass	4.6
- Shape, dimensions and colours	pass	4.7.2
- Symbols and lettering	pass	4.7.3
- Environment category	pass	4.7.5
- Additional requirements for software controlled manual call points	pass	4.8
- Test facility test (operational)	pass	5.4
- Reliability test (endurance)	pass	5.5
Durability of operational reliability, temperature resistance		
- Dry heat (operational)	pass	5.7
- Dry heat (endurance)	NA	5.8
- Cold (operational)	pass	5.9
Durability of operational reliability, vibration resistance		
- Shock (operational)	pass	5.14
- Impact (operational)	pass	5.15
- Vibration, sinusoidal (operational)	pass	5.16
- Vibration, sinusoidal (endurance)	pass	5.17
Durability of operational reliability, humidity resistance		
- Damp heat, cyclic (operational)	pass	5.10
- Damp heat, cyclic (endurance)	NA	5.11
- Damp heat, steady state (endurance)	pass	5.12
- Enclosure protection	NA	5.19
Durability of operational reliability, corrosion resistance		
- Damp heat, cyclic (endurance)	NA	5.11
- Sulphur dioxide (SO_2) corrosion (endurance)	pass	5.13
Durability of operational reliability, electrical stability		
- Variation of supply parameters	pass	5.6
- Electromagnetic compatibility (EMC), (operational)	pass	5.18
Note: NPD theoretically possible; except for durability of characteristics with declared performance NA (not applicable) for components to which the requirement does not apply		

Brussels, 24 October 2024

Marie Majerus
Certification Manager

This certificate and the annexes may only be copied completely and without any alteration.
cert@anpi.be - www.anpi.be

Notified body No. 1134
asbl **ANPI** vzw
Parc Scientifique Fleming - Granbonpré 1
B-1348 Louvain-la-Neuve

003-PROD
ISO/IEC 17065

Annex 3 to the CERTIFICATE CONSTANCY OF PERFORMANCE

1134-CPR-097

Harmonised technical specification	**EN 54-17:2005/AC:2007**	
Essential Characteristics	**Performance**	**Clause**
Performance under fire conditions - Reproducibility	 pass	 5.2
Operational reliability - Requirements	 pass	 4
Durability of operational reliability, temperature resistance - Dry heat (operational) - Cold (operational)	 pass pass	 5.4 5.5
Durability of operational reliability, vibration resistance - Shock (operational) - Impact (operational) - Vibration, sinusoidal (operational) - Vibration, sinusoidal (endurance)	 pass pass pass pass	 5.9 5.10 5.11 5.12
Durability of operational reliability, humidity resistance - Damp heat, cyclic (operational) - Damp heat, steady state (endurance)	 pass pass	 5.6 5.7
Durability of operational reliability, corrosion resistance - Sulphur dioxide (SO_2) corrosion (endurance)	 pass	 5.8
Durability of operational reliability, electrical stability - Variation in supply parameters - Electromagnetic compatibility (EMC), immunity tests (operational)	 pass pass	 5.3 5.13
Note: NPD theoretically possible; except for durability of characteristics with declared performance NA (not applicable) for components to which the requirement does not apply		

Brussels, 24 October 2024

Marie Majerus
Certification Manager

This certificate and the annexes may only be copied completely and without any alteration.
cert@anpi.be - www.anpi.be