Certificate of constancy of performance
0063-CPR-242190013
Issue: 01

Issued	11-12-2024	**Replaces**	0063-CPR-242190013 / 00
First issued	29-05-2024	**Page**	1 / 3

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Product description:	Siren + Visual Alarm Device
Trademark:	Kingspan
Type designation:	PHON-ASFW
Hardware / Software:	1 / 1
Conditions and essential characteristics:	See Annex 1
Variants:	See Annex 1

placed on the market under the name or trademark of:

Name of the manufacturer:	Kingspan Light + Air Belgium nv
Address:	Anthonis De Jonghestraat 50
City:	9100 Sint-Niklaas
Country:	België

and produced in the manufacturing plant(s):

Manufacturing plant:	Kingspan Light + Air Belgium nv
Address:	Anthonis De Jonghestraat 50
City:	9100 Sint-Niklaas
Country:	België

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN 54-17:2005
EN 54-17:2005/AC:2007
EN 54-23:2010
EN 54-3:2001
EN 54-3:2001/A1:2002
EN 54-3:2001/A2:2006

under system 1 for the performances set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the **constancy of performance of the construction product**

This certificate was first issued on 29-05-2024 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Ron Scheepers
Managing director

CERTIFICATE

Kiwa Nederland B.V.
Kiwa FSS Products
Wilmersdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

https://www.kiwa.com/nl/en/specials/fire-safety-and-security

Notified Body No. 0063

PRODUCTS
RvA C 002

Remarks and observations

The following conditions are applicable:

Essential characteristics EN 54-3	**Clauses in this European Standard**
Performance under fire conditions	4.2, 4.3, 5.2, 5.3
Operational reliability	4.4, 4.5, 4.6, 5.4
Durability of operational reliability: temperature resistance	5.5, 5.7, 5.8, 5.9
Durability of operational reliability: humidity resistance	5.8, 5.9
Durability of operational reliability: corrosion resistance	5.11
Durability of operational reliability: shock and vibration resistance	5.12 to 5.15
Durability of operational reliability: electrical stability	5.16
Durability of operational reliability: resistance to ingress	5.17

Essential characteristics EN 54-17	**Clauses in this European Standard**
Performance under fire conditions	5.2
Operational reliability	4
Durability of operational reliability: temperature resistance	5.4, 5.5
Durability of operational reliability: vibration resistance	5.9 to 5.12
Durability of operational reliability: humidity resistance	5.6, 5.7
Durability of operational reliability: corrosion resistance	5.8
Durability of operational reliability: electrical stability	5.3, 5.13

Essential characteristics EN 54-23	Clauses in this European Standard
Performance under fire conditions	4.3.1, 4.3.3, 4.3.6
Operational reliability	4.2.1 to 4.2.6, 4.2.8
Durability of operational reliability: temperature resistance	4.4.1
Durability of operational reliability: humidity resistance	4.4.2
Durability of operational reliability: corrosion resistance	4.4.4
Durability of operational reliability: shock and vibration resistance	4.4.3
Durability of operational reliability: electrical stability	4.4.5

The product as described in this certificate includes the following type designations

- Product description: Siren + Visual Alarm Device
- Trademark: Kingspan
- Type designation: PHON-ASFW
- Hardware version: 1
- Software version: 1

- Product description: Siren + Visual Alarm Device
- Trademark: Kingspan
- Type designation: PHON-ASFC
- Hardware version: 1
- Software version: 1